CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/BTR/W.No.14/CSR-08/109h/CUBE/2016-17 19.09.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*Customer	: **Asst. Executive Engineer,** T. Dasarahalli Sub Division, BBMP, Bangalore.
*Agency	: **Mr. B.T. Ravikumar,** No.180, 3rd Main, H.V.R. Layout, Magadi Road, Bangalore – 560 079.
*Name of the work	: Improvements to Road, Drain, Foot path BTS Layout and Sheshadri Layout in Bagalagunte in Ward No.14, BBMP, Bangalore.
Reference	: BBMP/DZ/AEE/TDSD/PR/215/2016-17 Dated: 03.08.2016
*Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
*Grade of Concrete	: M_{15}
Compressive Strength as on	: 28th day
Sample Received on	: 19.09.2016

Sl.No.	*Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	22.08.2016	19.09.2016	8.257	373.7	16.61
2	22.08.2016	19.09.2016	8.163	365.3	16.24
3	22.08.2016	19.09.2016	8.394	389.4	17.31

*Information is furnished by the Customer/Representative.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.



****

VISHWANATH .C
Quality Manager

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com